



GARLAND INDEPENDENT SCHOOL DISTRICT

PURCHASING DEPARTMENT

*501 S. Jupiter
Garland, Texas 75042*

July 23, 2025

ADDENDUM 1, RFP #135-26 (162591)

Vent A Hood Cleaning for SNS

This addendum modifies the original document as listed below and is hereby incorporated to the contract documents. Acknowledge receipt of this addendum by returning the completed and signed form with the solicitation response. Failure to submit the addendum may be used as an evaluated factor.

1. QUESTION:

Please provide details for the below,

- The size of each hood
- The number of filters per hood
- Whether the roof fans are connected to multiple hoods
- How many hoods are located in each school

RESPONSE:

- We do not have the size of each hood available. The largest hoods would be at our high school campuses and vary depending on the design of the school. Estimating that the largest hood area would be 30' long, with the majority of the hoods being 8'-10' long.
- For the typical 10' long hood, it would consist of 5 washable filter cartridges.
- The roof fans are connected to each hood and do not run multiple hoods.
- The count would vary based on campus. The majority of elementary schools have 1 hood (Est. 50-60). Middle school campuses will also have 1-2 hoods (Est. 20), and our high schools can have 3-6 hoods each due to different locations in the kitchen and concept lines (Est. 20-25).

Mayte R. Martinez
Mayte R. Martinez
Assistant Director of Purchasing

Company Name

Address

City

State

Zip

Signature

Title